


FROM THE DESK OF   
J. RANDALL LYMAN  
PRETREATMENT COORDINATOR  
CITY OF SPRINGFIELD  
1216 W. NICHOLS ST.  
SPRINGFIELD, MISSOURI 65802  
PHONE 417-864-1487  
FAX 417-864-1918

FILE 1530 W LOMBARD

June 20, 1997

WAYNE LATIMER, SEWER MAINTENANCE SUPERVISOR

BRIAN ADAMS OF THE AIR QUALITY SECTION AT EXT. 1412 IN THE HEALTH DEPARTMENT CALLED ME FIRST THING THIS MORNING TO INFORM US THAT HE WORKED A SEWER GAS ODOR COMPLAINT YESTERDAY AT **1530 W. LOMBARD**. HE INDICATED THAT A STORM SEWER IS IN CLOSE PROXIMITY TO THE CITY SANITARY SEWER AND HE CONFIRMED A SEWER GAS ODOR IN THE STORM SEWER SYSTEM. THE COMPLAINANT, SUSAN BUDDE, TOLD BRIAN THAT WHEN WE HAD THE BIG RAIN EVENT IN SEPTEMBER OF 1993 THAT THE MANHOLE COVER FOR THE SEWER BLEW OFF AND ALSO THERE WAS A LOT OF SEWAGE DEBRIS IN HER YARD AFTER THE FLOOD. IT APPEARS THAT WE MAY HAVE A "CROSS-CONNECTION" AT THIS LOCATION IF SEWER GAS IS IN FACT ESCAPING INTO THE STORM SEWER. I DID NOT HAVE MONICA DISPATCH A FLUSHER CREW TO THIS LOCATION; THOUGHT YOU MIGHT WANT TO CHECK THIS OUT FIRST. LET ME KNOW IF YOU NEED ANYTHING FROM US.

CC: GENE PABST  
MONICA COLLINS

1530 W. LOMBARD